

Compliance Maintenance Annual Report

Dorchester Wastewater Treatment Facility

Last Updated: Reporting For:
6/4/2018 2017

Resolution or Owner's Statement

Name of Governing
Body or Owner:

Village of Dorchester

Date of Resolution or
Action Taken:

Resolution Number:

303

Date of Submittal:

ACTIONS SET FORTH BY THE GOVERNING BODY OR OWNER RELATING TO SPECIFIC CMAR SECTIONS (Optional for grade A or B. Required for grade C, D, or F):

Influent Flow and Loadings: Grade = B

Effluent Quality: BOD: Grade = A

Effluent Quality: TSS: Grade = A

Effluent Quality: Ammonia: Grade = C

Due to thawing and freezing of ponds in February and March, that condition caused lowering temperature of water especially in upper ponds. Thus bugs quit working as far as NH3-N was concerned till water warmed up in spring and bugs started working again to lower NH3-N results

Effluent Quality: Phosphorus: Grade = A

Ponds: Grade = A

Biosolids Quality and Management: Grade = A

Staffing: Grade = A

Operator Certification: Grade = A

Financial Management: Grade = A

Collection Systems: Grade = A

(Regardless of grade, response required for Collection Systems if SSOs were reported)

ACTIONS SET FORTH BY THE GOVERNING BODY OR OWNER RELATING TO THE OVERALL GRADE POINT AVERAGE AND ANY GENERAL COMMENTS

(Optional for G.P.A. greater than or equal to 3.00, required for G.P.A. less than 3.00)

G.P.A. = 3.70

Compliance Maintenance Annual Report

Dorchester Wastewater Treatment Facility

Last Updated: Reporting For:
6/4/2018 2017

Grading Summary

WPDES No: 0021571

SECTIONS	LETTER GRADE	GRADE POINTS	WEIGHTING FACTORS	SECTION POINTS
Influent	B	3	3	9
BOD/CBOD	A	4	10	40
TSS	A	4	5	20
Ammonia	C	2	5	10
Phosphorus	A	4	3	12
Ponds	A	4	7	28
Biosolids	A	4	5	20
Staffing/PM	A	4	1	4
OpCert	A	4	1	4
Financial	A	4	1	4
Collection	A	4	3	12
TOTALS			44	163
GRADE POINT AVERAGE (GPA) = 3.70				

Notes:

- A = Voluntary Range (Response Optional)
- B = Voluntary Range (Response Optional)
- C = Recommendation Range (Response Required)
- D = Action Range (Response Required)
- F = Action Range (Response Required)