

Compliance Maintenance Annual Report

Dorchester Wastewater Treatment Facility

Last Updated: Reporting For:

5/26/2021

2020

Influent Flow and Loading

1. Monthly Average Flows and BOD Loadings

1.1 Verify the following monthly flows and BOD loadings to your facility.

Influent No. 701	Influent Monthly Average Flow, MGD	x	Influent Monthly Average BOD Concentration mg/L	x	8.34	=	Influent Monthly Average BOD Loading, lbs/day
January	0.0985	x	237	x	8.34	=	194
February	0.0780	x	246	x	8.34	=	160
March	0.1785	x	140	x	8.34	=	208
April	0.1395	x	137	x	8.34	=	159
May	0.1118	x	231	x	8.34	=	215
June	0.1142	x	222	x	8.34	=	212
July	0.1164	x	258	x	8.34	=	250
August	0.0806	x	466	x	8.34	=	313
September	0.0769	x	254	x	8.34	=	163
October	0.0777	x	204	x	8.34	=	132
November	0.1069	x	180	x	8.34	=	160
December	0.0815	x	276	x	8.34	=	188

2. Maximum Monthly Design Flow and Design BOD Loading

2.1 Verify the design flow and loading for your facility.

Design	Design Factor	x	%	=	% of Design
Max Month Design Flow, MGD	.128	x	90	=	0.1152
		x	100	=	.128
Design BOD, lbs/day	304	x	90	=	273.6
		x	100	=	304

2.2 Verify the number of times the flow and BOD exceeded 90% or 100% of design, points earned, and score:

	Months of Influent	Number of times flow was greater than 90% of	Number of times flow was greater than 100% of	Number of times BOD was greater than 90% of design	Number of times BOD was greater than 100% of design
January	1	0	0	0	0
February	1	0	0	0	0
March	1	1	1	0	0
April	1	1	1	0	0
May	1	0	0	0	0
June	1	0	0	0	0
July	1	1	0	0	0
August	1	0	0	1	1
September	1	0	0	0	0
October	1	0	0	0	0
November	1	0	0	0	0
December	1	0	0	0	0
Points per each		2	1	3	2
Exceedances		3	2	1	1
Points		6	2	3	2
Total Number of Points					13

Compliance Maintenance Annual Report

Dorchester Wastewater Treatment Facility

Last Updated: Reporting For:

5/26/2021

2020

3. Flow Meter

3.1 Was the influent flow meter calibrated in the last year?

Yes Enter last calibration date (MM/DD/YYYY)

No

If No, please explain:

4. Sewer Use Ordinance

4.1 Did your community have a sewer use ordinance that limited or prohibited the discharge of excessive conventional pollutants ((C)BOD, SS, or pH) or toxic substances to the sewer from industries, commercial users, hauled waste, or residences?

Yes

No

If No, please explain:

4.2 Was it necessary to enforce the ordinance?

Yes

No

If Yes, please explain:

5. Septage Receiving

5.1 Did you have requests to receive septage at your facility?

Septic Tanks Holding Tanks Grease Traps

Yes

Yes

Yes

No

No

No

5.2 Did you receive septage at your facility? If yes, indicate volume in gallons.

Septic Tanks

Yes

gallons

No

Holding Tanks

Yes

gallons

No

Grease Traps

Yes

gallons

No

5.2.1 If yes to any of the above, please explain if plant performance is affected when receiving any of these wastes.

6. Pretreatment

6.1 Did your facility experience operational problems, permit violations, biosolids quality concerns, or hazardous situations in the sewer system or treatment plant that were attributable to commercial or industrial discharges in the last year?

Yes

No

If yes, describe the situation and your community's response.

6.2 Did your facility accept hauled industrial wastes, landfill leachate, etc.?

Compliance Maintenance Annual Report

Dorchester Wastewater Treatment Facility

Last Updated: Reporting For:
5/26/2021 2020

<p><input type="radio"/> Yes</p> <p><input checked="" type="radio"/> No</p> <p>If yes, describe the types of wastes received and any procedures or other restrictions that were in place to protect the facility from the discharge of hauled industrial wastes.</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>	
--	--

Total Points Generated	13
Score (100 - Total Points Generated)	87
Section Grade	B

Compliance Maintenance Annual Report

Dorchester Wastewater Treatment Facility

Last Updated: Reporting For:

5/26/2021

2020

Effluent Quality and Plant Performance (BOD/CBOD)

1. Effluent (C)BOD Results

1.1 Verify the following monthly average effluent values, exceedances, and points for BOD or CBOD

Outfall No. 001	Monthly Average Limit (mg/L)	90% of Permit Limit > 10 (mg/L)	Effluent Monthly Average (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance	90% Permit Limit Exceedance
January	12	10.8	1	1	0	0
February	12	10.8	2	1	0	0
March	25	22.5	6	1	0	0
April	25	22.5	9	1	0	0
May	25	22.5	12	1	0	0
June	10	10				
July	12	10.8	8	1	0	0
August	12	10.8	7	1	0	0
September	12	10.8	7	1	0	0
October	12	10.8	8	1	0	0
November	12	10.8	5	1	0	0
December	12	10.8	4	1	0	0

* Equals limit if limit is <= 10

Months of discharge/yr	11		
Points per each exceedance with 11 months of discharge		8	3
Exceedances		0	0
Points		0	0
Total number of points			0

NOTE: For systems that discharge intermittently to state waters, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge. Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is $12/6 = 2.0$

1.2 If any violations occurred, what action was taken to regain compliance?

N/A

2. Flow Meter Calibration

2.1 Was the effluent flow meter calibrated in the last year?

Yes

Enter last calibration date (MM/DD/YYYY)

2020-10-13

No

If No, please explain:

N/A

3. Treatment Problems

3.1 What problems, if any, were experienced over the last year that threatened treatment?

N/A

4. Other Monitoring and Limits

4.1 At any time in the past year was there an exceedance of a permit limit for any other pollutants such as chlorides, pH, residual chlorine, fecal coliform, or metals?

Yes

No

Compliance Maintenance Annual Report

Dorchester Wastewater Treatment Facility

Last Updated: Reporting For:

5/26/2021

2020

If Yes, please explain:

4.2 At any time in the past year was there a failure of an effluent acute or chronic whole effluent toxicity (WET) test?

Yes

No

If Yes, please explain:

4.3 If the biomonitoring (WET) test did not pass, were steps taken to identify and/or reduce source(s) of toxicity?

Yes

No

N/A

Please explain unless not applicable:

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Dorchester Wastewater Treatment Facility

Last Updated: Reporting For:

5/26/2021

2020

Effluent Quality and Plant Performance (Total Suspended Solids)

1. Effluent Total Suspended Solids Results

1.1 Verify the following monthly average effluent values, exceedances, and points for TSS:

Outfall No. 001	Monthly Average Limit (mg/L)	90% of Permit Limit >10 (mg/L)	Effluent Monthly Average (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance	90% Permit Limit Exceedance
January	60	54	3	1	0	0
February	60	54	3	1	0	0
March	60	54	6	1	0	0
April	60	54	22	1	0	0
May	60	54	55	1	0	1
June	10	10				
July	60	54	30	1	0	0
August	60	54	16	1	0	0
September	60	54	28	1	0	0
October	60	54	17	1	0	0
November	60	54	14	1	0	0
December	60	54	23	1	0	0
* Equals limit if limit is <= 10						
Months of Discharge/yr				11		
Points per each exceedance with 11 months of discharge:					8	3
Exceedances					0	1
Points					0	3
Total Number of Points						3

3

NOTE: For systems that discharge intermittently to state waters, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge.

Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is $12/6 = 2.0$

1.2 If any violations occurred, what action was taken to regain compliance?

N/A

Total Points Generated	3
Score (100 - Total Points Generated)	97
Section Grade	A

Compliance Maintenance Annual Report

Dorchester Wastewater Treatment Facility

Last Updated: Reporting For:

5/26/2021

2020

Effluent Quality and Plant Performance (Ammonia - NH3)

1. Effluent Ammonia Results

1.1 Verify the following monthly and weekly average effluent values, exceedances and points for ammonia

Outfall No. 001	Monthly Average NH3 Limit (mg/L)	Weekly Average NH3 Limit (mg/L)	Effluent Monthly Average NH3 (mg/L)	Monthly Permit Limit Exceedance	Effluent Weekly Average for Week 1	Effluent Weekly Average for Week 2	Effluent Weekly Average for Week 3	Effluent Weekly Average for Week 4	Weekly Permit Limit Exceedance
January	6.5		2.96	0					
February	6.5		5.35	0					
March	10		7.825	0					
April	13		7.3	0					
May	11		2.4	0					
June	2.6			0					
July	2.3		0	0					
August	2.5		.95	0					
September	3.6		.2	0					
October	5.7		.275	0					
November	7.2		.75	0					
December	6.5		1.86	0					
Points per each exceedance of Monthly average:									10
Exceedances, Monthly:									0
Points:									0
Points per each exceedance of weekly average (when there is no monthly average):									2.5
Exceedances, Weekly:									0
Points:									0
Total Number of Points									0

0

NOTE: Limit exceedances are considered for monthly OR weekly averages but not both. When a monthly average limit exists it will be used to determine exceedances and generate points. This will be true even if a weekly limit also exists. When a weekly average limit exists and a monthly limit does not exist, the weekly limit will be used to determine exceedances and generate points.

1.2 If any violations occurred, what action was taken to regain compliance?

N/A

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Dorchester Wastewater Treatment Facility

Last Updated: Reporting For:
5/26/2021 **2020**

Effluent Quality and Plant Performance (Phosphorus)

1. Effluent Phosphorus Results

1.1 Verify the following monthly average effluent values, exceedances, and points for Phosphorus

Outfall No. 001	Monthly Average phosphorus Limit (mg/L)	Effluent Monthly Average phosphorus (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance
January	8	3.948	1	0
February	8	4.945	1	0
March	8	6.083	1	0
April	8	1.498	1	0
May	8	2.005	1	0
June	8			
July	8	0.400	1	0
August	8	0.243	1	0
September	8	0.520	1	0
October	8	0.435	1	0
November	8	0.588	1	0
December	8	1.010	1	0
Months of Discharge/yr			11	
Points per each exceedance with 11 months of discharge:				11
Exceedances				0
Total Number of Points				0

0

NOTE: For systems that discharge intermittently to waters of the state, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge.

Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is $12/6 = 2.0$

1.2 If any violations occurred, what action was taken to regain compliance?

N/A

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Dorchester Wastewater Treatment Facility

Last Updated: Reporting For:

5/26/2021

2020

Ponds And Lagoon Leakage

1. Pond Lining

1.1 What material was used to line your ponds?

Ponds 1, 2 and 3 - Clay
Ponds 3 and 4 - PVC

2. Flow Measurements

2.1 Did you measure influent flow to your wastewater ponds or lagoons?

- Yes (0 points)
- No (40 points) (Go to question 6)

2.1.1 Method of influent flow measurement:

Electromagnetic Flow Meter

2.2 Did you measure effluent flow discharged from your wastewater system either to the land disposal system or to the receiving stream?

- Yes (0 points)
- No (40 points) (Go to question 6)
- No Discharge (0 points)

2.2.1 Method of effluent flow measurement:

Electromagnetic Flow Meter

0

3. Total Flow Volumes

3.1 Total monthly influent and effluent flow volumes from the pond/lagoon system during the last calendar year.

Total Monthly Influent Volume		Total Monthly Effluent Volume
3.052	JANUARY	3.913
2.263	FEBRUARY	3.479
5.533	MARCH	5.877
4.186	APRIL	5.701
3.465	MAY	5.522
3.427	JUNE	
3.608	JULY	2.93
2.498	AUGUST	2.331
2.306	SEPTEMBER	1.988
2.409	OCTOBER	4.787
3.208	NOVEMBER	5.443
2.526	DECEMBER	2.06
38.4810	YEARLY TOTAL	44.0310

3.2 From the Yearly Total influent and effluent volumes above, total effluent is divided by total influent and converted to a percent of volume loss.

$$\frac{\text{Total effluent, MG} \Rightarrow 44.0310}{\text{Total influent, MG} \Rightarrow 38.4810} = 1.144 \leq \text{effl / infl ratio}$$

Conversion to a percent of volume loss:

$$(1 - \text{effl/infl ratio}) * 100 = -14.4$$

Compliance Maintenance Annual Report

Dorchester Wastewater Treatment Facility

Last Updated: Reporting For:

5/26/2021

2020

% of influent lost and not discharged with effluent

4. Surface Area

4.1 What was the total wastewater surface area of the ponds/lagoons at operating level (do not include seepage cells)?

9.1 Acres

5. Leakage Rate Estimation

5.1 Total influent volume (in MG) minus total effluent volume (in MG) plus or minus the change in pond/lagoon storage (in MG) is the net wastewater loss. The net loss divided by 0.000365 equals the estimated leakage amount in gpd.

Total Annual Influent (MG)	38.4810	
Total Annual Effluent (MG)	44.0310	
Estimated Net Loss (MG)	-5.5500	
Estimated Leakage Amount (gpd)		-15205

If you have a *Department approved* method for determining a change in storage volume, enter the storage change last year in MG below.

o Storage Increase: Enter amount in MG ->

o Storage Decrease: Enter amount in MG ->

5.2 CMAR Estimated Leakage Rate in gallons per acre per day (gpad): The CMAR Estimated Leakage Rate in gpad is the leakage amount in gpd (from part 5.1) divided by the total pond surface area (from question 4).

Leakage Amount (gpd)		Acres		CMAR Estimated Leakage Rate
-15205	divided by	9.1	=	-1671

6. On Site Leakage Testing

6.1 Did you conduct an on-site, field water balance/leakage test on your ponds or lagoons that was approved by the Department and is still valid?

o Yes Year

● No

If yes, what was the field Test Calculated Leakage Rate for your ponds/lagoons?

gpad

NOTE: if 6.1 is answered Yes, the value entered above in gpad will be used in 7.1 to compute points generated.

6.2 Leakage Rate Comments:

7. Estimated Leakage Rate and Points

7.1 The CMAR Estimated Leakage Rate (from 5) is used to determine the points generated in the table below.

If an approved field test was conducted and the results are still valid and accepted by the Department, the Field Calculated Leakage rate (from 5.2) is used to determine the points earned from the table below

Compliance Maintenance Annual Report

Dorchester Wastewater Treatment Facility

Last Updated: Reporting For:
5/26/2021 2020

gpad	points	0
0 - 1,000	0	
1,001 - 2,000	10	
2,001 - 4,000	20	
4,001 - 7,000	30	
> 7,000	40	

Based on the leakage rate in gpad, the points earned are:

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Dorchester Wastewater Treatment Facility

Last Updated: Reporting For:

5/26/2021

2020

Biosolids Quality and Management

<p>1. Biosolids Use/Disposal</p> <p>1.1 How did you use or dispose of your biosolids? (Check all that apply)</p> <p><input type="checkbox"/> Land applied under your permit</p> <p><input type="checkbox"/> Publicly Distributed Exceptional Quality Biosolids</p> <p><input type="checkbox"/> Hauled to another permitted facility</p> <p><input type="checkbox"/> Landfilled</p> <p><input type="checkbox"/> Incinerated</p> <p><input checked="" type="checkbox"/> Other</p> <p>NOTE: If you did not remove biosolids from your system, please describe your system type such as lagoons, reed beds, recirculating sand filters, etc.</p> <p>1.1.1 If you checked Other, please describe:</p> <div style="border: 1px solid black; padding: 2px; margin-top: 5px;">Lagoons</div>	
<p>6. Biosolids Storage</p> <p>6.1 How many days of actual, current biosolids storage capacity did your wastewater treatment facility have either on-site or off-site?</p> <p><input type="radio"/> >= 180 days (0 Points)</p> <p><input type="radio"/> 150 - 179 days (10 Points)</p> <p><input type="radio"/> 120 - 149 days (20 Points)</p> <p><input type="radio"/> 90 - 119 days (30 Points)</p> <p><input type="radio"/> < 90 days (40 Points)</p> <p><input checked="" type="radio"/> N/A (0 Points)</p> <p>6.2 If you checked N/A above, explain why.</p> <div style="border: 1px solid black; padding: 2px; margin-top: 5px;">Lagoons</div>	0
<p>7. Issues</p> <p>7.1 Describe any outstanding biosolids issues with treatment, use or overall management:</p> <div style="border: 1px solid black; padding: 2px; margin-top: 5px;">N/A</div>	

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Dorchester Wastewater Treatment Facility

Last Updated: Reporting For:

5/26/2021

2020

Staffing and Preventative Maintenance (All Treatment Plants)

<p>1. Plant Staffing</p> <p>1.1 Was your wastewater treatment plant adequately staffed last year?</p> <ul style="list-style-type: none">● Yes○ No <p>If No, please explain:</p> <div style="border: 1px solid black; padding: 2px;">N/A</div> <p>Could use more help/staff for:</p> <div style="border: 1px solid black; padding: 2px;">N/A</div> <p>1.2 Did your wastewater staff have adequate time to properly operate and maintain the plant and fulfill all wastewater management tasks including recordkeeping?</p> <ul style="list-style-type: none">● Yes○ No <p>If No, please explain:</p> <div style="border: 1px solid black; padding: 2px;">N/A</div>	
<p>2. Preventative Maintenance</p> <p>2.1 Did your plant have a documented AND implemented plan for preventative maintenance on major equipment items?</p> <ul style="list-style-type: none">● Yes (Continue with question 2) <input type="checkbox"/>○ No (40 points) <input type="checkbox"/> <p>If No, please explain, then go to question 3:</p> <div style="border: 1px solid black; height: 20px;"></div> <p>2.2 Did this preventative maintenance program depict frequency of intervals, types of lubrication, and other tasks necessary for each piece of equipment?</p> <ul style="list-style-type: none">● Yes○ No (10 points) <p>2.3 Were these preventative maintenance tasks, as well as major equipment repairs, recorded and filed so future maintenance problems can be assessed properly?</p> <ul style="list-style-type: none">● Yes<ul style="list-style-type: none">○ Paper file system○ Computer system● Both paper and computer system○ No (10 points)	0
<p>3. O&M Manual</p> <p>3.1 Does your plant have a detailed O&M and Manufacturer Equipment Manuals that can be used as a reference when needed?</p> <ul style="list-style-type: none">● Yes○ No	
<p>4. Overall Maintenance /Repairs</p> <p>4.1 Rate the overall maintenance of your wastewater plant.</p> <ul style="list-style-type: none">○ Excellent○ Very good● Good○ Fair○ Poor <p>Describe your rating:</p> <div style="border: 1px solid black; padding: 2px;">Up to this point, it functions well for current permit</div>	

Compliance Maintenance Annual Report

Dorchester Wastewater Treatment Facility

Last Updated: Reporting For:
5/26/2021 **2020**

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Dorchester Wastewater Treatment Facility

Last Updated: Reporting For:

5/26/2021

2020

Operator Certification and Education

1. Operator-In-Charge

1.1 Did you have a designated operator-in-charge during the report year?

- Yes (0 points)
- No (20 points)

Name:

RICHARD P GOLZ

Certification No:

34402

0

2. Certification Requirements

2.1 In accordance with Chapter NR 114.56 and 114.57, Wisconsin Administrative Code, what level and subclass(es) were required for the operator-in-charge (OIC) to operate the wastewater treatment plant and what level and subclass(es) were held by the operator-in-charge?

Sub Class	SubClass Description	WWTP	OIC		
		Basic	OIT	Basic	Advanced
A1	Suspended Growth Processes				
A2	Attached Growth Processes				
A3	Recirculating Media Filters				
A4	Ponds, Lagoons and Natural	X		X	
A5	Anaerobic Treatment Of Liquid				
B	Solids Separation				
C	Biological Solids/Sludges				
P	Total Phosphorus				
N	Total Nitrogen				
D	Disinfection				
L	Laboratory				
U	Unique Treatment Systems				
SS	Sanitary Sewage Collection	X	NA	NA	NA

2.2 Was the operator-in-charge certified at the appropriate level and subclass(es) to operate this plant? (Note: Certification in subclass SS is required 5 years after permit reissuance and is basic level only.)

- Yes (0 points)
- No (20 points)

0

3. Succession Planning

3.1 In the event of the loss of your designated operator-in-charge, did you have a contingency plan to ensure the continued proper operation and maintenance of the plant that includes one or more of the following options (check all that apply)?

- One or more additional certified operators on staff
- An arrangement with another certified operator
- An arrangement with another community with a certified operator
- An operator on staff who has an operator-in-training certificate for your plant and is expected to be certified within one year
- A consultant to serve as your certified operator
- None of the above (20 points)

If "None of the above" is selected, please explain:

0

4. Continuing Education Credits

Compliance Maintenance Annual Report

Dorchester Wastewater Treatment Facility

Last Updated: Reporting For:
5/26/2021 2020

4.1 If you had a designated operator-in-charge, was the operator-in-charge earning Continuing Education Credits at the following rates? OIT and Basic Certification: <input checked="" type="radio"/> Averaging 6 or more CECs per year. <input type="radio"/> Averaging less than 6 CECs per year. Advanced Certification: <input type="radio"/> Averaging 8 or more CECs per year. <input type="radio"/> Averaging less than 8 CECs per year.	
---	--

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Dorchester Wastewater Treatment Facility

Last Updated: Reporting For:

5/26/2021

2020

Financial Management

<p>1. Provider of Financial Information</p> <p>Name: <input style="width: 300px;" type="text" value="Christie Erickson"/></p> <p>Telephone: <input style="width: 150px;" type="text" value="715-654-5006"/> (XXX) XXX-XXXX</p> <p>E-Mail Address (optional): <input style="width: 150px;" type="text"/></p>													
<p>2. Treatment Works Operating Revenues</p> <p>2.1 Are User Charges or other revenues sufficient to cover O&M expenses for your wastewater treatment plant AND/OR collection system ?</p> <p>● Yes (0 points) <input type="checkbox"/><input type="checkbox"/></p> <p>○ No (40 points)</p> <p>If No, please explain:</p> <div style="border: 1px solid black; padding: 2px; width: fit-content;">N/A</div> <p>2.2 When was the User Charge System or other revenue source(s) last reviewed and/or revised?</p> <p>Year: <input style="width: 100px;" type="text" value="2020"/></p> <p>● 0-2 years ago (0 points) <input type="checkbox"/><input type="checkbox"/></p> <p>○ 3 or more years ago (20 points) <input type="checkbox"/><input type="checkbox"/></p> <p>○ N/A (private facility)</p> <p>2.3 Did you have a special account (e.g., CWFP required segregated Replacement Fund, etc.) or financial resources available for repairing or replacing equipment for your wastewater treatment plant and/or collection system?</p> <p>● Yes (0 points)</p> <p>○ No (40 points)</p>	0												
<p>REPLACEMENT FUNDS [PUBLIC MUNICIPAL FACILITIES SHALL COMPLETE QUESTION 3]</p>													
<p>3. Equipment Replacement Funds</p> <p>3.1 When was the Equipment Replacement Fund last reviewed and/or revised?</p> <p>Year: <input style="width: 150px;" type="text" value="2019"/></p> <p>● 1-2 years ago (0 points) <input type="checkbox"/><input type="checkbox"/></p> <p>○ 3 or more years ago (20 points) <input type="checkbox"/><input type="checkbox"/></p> <p>○ N/A</p> <p>If N/A, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div> <p>3.2 Equipment Replacement Fund Activity</p> <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 60%;">3.2.1 Ending Balance Reported on Last Year's CMAR</td> <td style="width: 5%; text-align: center;">\$</td> <td style="width: 35%; text-align: right;"><input style="width: 100%;" type="text" value="7,046.77"/></td> </tr> <tr> <td>3.2.2 Adjustments - if necessary (e.g. earned interest, audit correction, withdrawal of excess funds, increase making up previous shortfall, etc.)</td> <td style="text-align: center;">\$</td> <td style="text-align: right;"><input style="width: 100%;" type="text" value="0.00"/></td> </tr> <tr> <td>3.2.3 Adjusted January 1st Beginning Balance</td> <td style="text-align: center;">\$</td> <td style="text-align: right;"><input style="width: 100%;" type="text" value="7,046.77"/></td> </tr> <tr> <td>3.2.4 Additions to Fund (e.g. portion of User Fee, earned interest, etc.)</td> <td style="text-align: center;">+</td> <td style="text-align: right;"><input style="width: 100%;" type="text" value="22,908.00"/></td> </tr> </table>	3.2.1 Ending Balance Reported on Last Year's CMAR	\$	<input style="width: 100%;" type="text" value="7,046.77"/>	3.2.2 Adjustments - if necessary (e.g. earned interest, audit correction, withdrawal of excess funds, increase making up previous shortfall, etc.)	\$	<input style="width: 100%;" type="text" value="0.00"/>	3.2.3 Adjusted January 1st Beginning Balance	\$	<input style="width: 100%;" type="text" value="7,046.77"/>	3.2.4 Additions to Fund (e.g. portion of User Fee, earned interest, etc.)	+	<input style="width: 100%;" type="text" value="22,908.00"/>	
3.2.1 Ending Balance Reported on Last Year's CMAR	\$	<input style="width: 100%;" type="text" value="7,046.77"/>											
3.2.2 Adjustments - if necessary (e.g. earned interest, audit correction, withdrawal of excess funds, increase making up previous shortfall, etc.)	\$	<input style="width: 100%;" type="text" value="0.00"/>											
3.2.3 Adjusted January 1st Beginning Balance	\$	<input style="width: 100%;" type="text" value="7,046.77"/>											
3.2.4 Additions to Fund (e.g. portion of User Fee, earned interest, etc.)	+	<input style="width: 100%;" type="text" value="22,908.00"/>											

Compliance Maintenance Annual Report

Dorchester Wastewater Treatment Facility

Last Updated: Reporting For:
5/26/2021 2020

3.2.5 Subtractions from Fund (e.g., equipment replacement, major repairs - use description box 3.2.6.1 below*) -

\$ 0.00

3.2.6 Ending Balance as of December 31st for CMAR Reporting Year

\$ 29,954.77

All Sources: This ending balance should include all Equipment Replacement Funds whether held in a bank account(s), certificate(s) of deposit, etc.

3.2.6.1 Indicate adjustments, equipment purchases, and/or major repairs from 3.2.5 above.

Chemicals for Phosphorus

3.3 What amount should be in your Replacement Fund?

\$ 2,000.00

0

Please note: If you had a CWF loan, this amount was originally based on the Financial Assistance Agreement (FAA) and should be regularly updated as needed. Further calculation instructions and an example can be found by clicking the SectionInstructions link under Info header in the left-side menu.

3.3.1 Is the December 31 Ending Balance in your Replacement Fund above, (#3.2.6) equal to, or greater than the amount that should be in it (#3.3)?

- Yes
- No

If No, please explain.

4. Future Planning

4.1 During the next ten years, will you be involved in formal planning for upgrading, rehabilitating, or new construction of your treatment facility or collection system?

- Yes - If Yes, please provide major project information, if not already listed below.
- No

Project #	Project Description	Estimated Cost	Approximate Construction Year
1	Phosphorus Removal, Looking at upgrading Lift Station on HWY A	3500000	2024

5. Financial Management General Comments

N/A

ENERGY EFFICIENCY AND USE

6. Collection System

6.1 Energy Usage

6.1.1 Enter the monthly energy usage from the different energy sources:

COLLECTION SYSTEM PUMPAGE: Total Power Consumed

Number of Municipally Owned Pump/Lift Stations:

Compliance Maintenance Annual Report

Dorchester Wastewater Treatment Facility

Last Updated: Reporting For:
5/26/2021 **2020**

	Electricity Consumed (kWh)	Natural Gas Consumed (therms)
January	459	
February	514	
March	543	
April	621	
May	576	
June	522	
July	396	
August	333	
September	192	
October	110	
November	233	
December	266	
Total	4,765	0
Average	397	0

6.1.2 Comments:

This kWh is for 1 of the 3 lift stations as the other 2 lift stations are metered together with the main WWTP meter

6.2 Energy Related Processes and Equipment

6.2.1 Indicate equipment and practices utilized at your pump/lift stations (Check all that apply):

- Comminution or Screening
- Extended Shaft Pumps
- Flow Metering and Recording
- Pneumatic Pumping
- SCADA System
- Self-Priming Pumps
- Submersible Pumps
- Variable Speed Drives
- Other:

6.2.2 Comments:

6.3 Has an Energy Study been performed for your pump/lift stations?

● No

○ Yes

Year:

By Whom:

Describe and Comment:

Compliance Maintenance Annual Report

Dorchester Wastewater Treatment Facility

Last Updated: Reporting For:

5/26/2021

2020

6.4 Future Energy Related Equipment

6.4.1 What energy efficient equipment or practices do you have planned for the future for your pump/lift stations?

New lift station on HWY A

7. Treatment Facility

7.1 Energy Usage

7.1.1 Enter the monthly energy usage from the different energy sources:

TREATMENT PLANT: Total Power Consumed/Month

	Electricity Consumed (kWh)	Total Influent Flow (MG)	Electricity Consumed/Flow (kWh/MG)	Total Influent BOD (1000 lbs)	Electricity Consumed/Total Influent BOD (kWh/1000lbs)	Natural Gas Consumed (therms)
January	21,947	3.05	7,196	6.01	3,652	
February	20,023	2.26	8,860	4.64	4,315	
March	19,753	5.53	3,572	6.45	3,062	
April	19,474	4.19	4,648	4.77	4,083	
May	20,162	3.47	5,810	6.67	3,023	
June	18,074	3.43	5,269	6.36	2,842	
July	16,586	3.61	4,594	7.75	2,140	
August	16,647	2.50	6,659	9.70	1,716	
September	15,364	2.31	6,651	4.89	3,142	
October	17,313	2.41	7,184	4.09	4,233	
November	15,478	3.21	4,822	4.80	3,225	
December	16,640	2.53	6,577	5.83	2,854	
Total	217,461	38.50		71.96		0
Average	18,122	3.21	5,987	6.00	3,191	0

7.1.2 Comments:

This information on kWh includes the blowers on the upper ponds and 2 lift stations and blowers on lower ponds

7.2 Energy Related Processes and Equipment

7.2.1 Indicate equipment and practices utilized at your treatment facility (Check all that apply):

- Aerobic Digestion
- Anaerobic Digestion
- Biological Phosphorus Removal
- Coarse Bubble Diffusers
- Dissolved O2 Monitoring and Aeration Control
- Effluent Pumping
- Fine Bubble Diffusers
- Influent Pumping
- Mechanical Sludge Processing
- Nitrification
- SCADA System
- UV Disinfection
- Variable Speed Drives

Compliance Maintenance Annual Report

Dorchester Wastewater Treatment Facility

Last Updated: Reporting For:

5/26/2021

2020

Other:

7.2.2 Comments:

N/A

7.3 Future Energy Related Equipment

7.3.1 What energy efficient equipment or practices do you have planned for the future for your treatment facility?

None at this time

8. Biogas Generation

8.1 Do you generate/produce biogas at your facility?

No

Yes

If Yes, how is the biogas used (Check all that apply):

Flared Off

Building Heat

Process Heat

Generate Electricity

Other:

9. Energy Efficiency Study

9.1 Has an Energy Study been performed for your treatment facility?

No

Yes

Entire facility

Year:

By Whom:

Describe and Comment:

Part of the facility

Year:

By Whom:

Describe and Comment:

Compliance Maintenance Annual Report

Dorchester Wastewater Treatment Facility

Last Updated: Reporting For:
5/26/2021 2020

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Dorchester Wastewater Treatment Facility

Last Updated: Reporting For:

5/26/2021

2020

Sanitary Sewer Collection Systems

1. Capacity, Management, Operation, and Maintenance (CMOM) Program

1.1 Do you have a CMOM program that is being implemented?

- Yes
- No

If No, explain:

1.2 Do you have a CMOM program that contains all the applicable components and items according to Wisc. Adm Code NR 210.23 (4)?

- Yes
- No (30 points)
- N/A

If No or N/A, explain:

1.3 Does your CMOM program contain the following components and items? (check the components and items that apply)

Goals [NR 210.23 (4)(a)]

Describe the major goals you had for your collection system last year:

Did you accomplish them?

- Yes
- No

If No, explain:

Organization [NR 210.23 (4) (b)]

Does this chapter of your CMOM include:

- Organizational structure and positions (eg. organizational chart and position descriptions)
- Internal and external lines of communication responsibilities
- Person(s) responsible for reporting overflow events to the department and the public

Legal Authority [NR 210.23 (4) (c)]

What is the legally binding document that regulates the use of your sewer system?

If you have a Sewer Use Ordinance or other similar document, when was it last reviewed and revised? (MM/DD/YYYY)

Does your sewer use ordinance or other legally binding document address the following:

- Private property inflow and infiltration
- New sewer and building sewer design, construction, installation, testing and inspection
- Rehabilitated sewer and lift station installation, testing and inspection
- Sewage flows satellite system and large private users are monitored and controlled, as necessary
- Fat, oil and grease control
- Enforcement procedures for sewer use non-compliance

Operation and Maintenance [NR 210.23 (4) (d)]

Does your operation and maintenance program and equipment include the following:

- Equipment and replacement part inventories
- Up-to-date sewer system map
- A management system (computer database and/or file system) for collection system information for O&M activities, investigation and rehabilitation

Compliance Maintenance Annual Report

Dorchester Wastewater Treatment Facility

Last Updated: Reporting For:

5/26/2021

2020

- A description of routine operation and maintenance activities (see question 2 below)
- Capacity assessment program
- Basement back assessment and correction
- Regular O&M training

Design and Performance Provisions [NR 210.23 (4) (e)]

What standards and procedures are established for the design, construction, and inspection of the sewer collection system, including building sewers and interceptor sewers on private property?

- State Plumbing Code, DNR NR 110 Standards and/or local Municipal Code Requirements
- Construction, Inspection, and Testing
- Others:

Overflow Emergency Response Plan [NR 210.23 (4) (f)]

Does your emergency response capability include:

- Responsible personnel communication procedures
- Response order, timing and clean-up
- Public notification protocols
- Training
- Emergency operation protocols and implementation procedures

Annual Self-Auditing of your CMOM Program [NR 210.23 (5)]

Special Studies Last Year (check only those that apply):

- Infiltration/Inflow (I/I) Analysis
- Sewer System Evaluation Survey (SSES)
- Sewer Evaluation and Capacity Management Plan (SECAP)
- Lift Station Evaluation Report
- Others:

Piloting chemicals for phosphorus removal in lagoons

0

2. Operation and Maintenance

2.1 Did your sanitary sewer collection system maintenance program include the following maintenance activities? Complete all that apply and indicate the amount maintained.

Cleaning	<input type="text" value="30"/>	% of system/year
Root removal	<input type="text" value="1"/>	% of system/year
Flow monitoring	<input type="text" value="0"/>	% of system/year
Smoke testing	<input type="text" value="0"/>	% of system/year
Sewer line televising	<input type="text" value="10"/>	% of system/year
Manhole inspections	<input type="text" value="25"/>	% of system/year
Lift station O&M	<input type="text" value="100"/>	# per L.S./year
Manhole rehabilitation	<input type="text" value="1"/>	% of manholes rehabbed
Mainline rehabilitation	<input type="text" value="1"/>	% of sewer lines rehabbed
Private sewer inspections	<input type="text" value="2"/>	% of system/year
Private sewer I/I removal	<input type="text" value="0"/>	% of private services

Compliance Maintenance Annual Report

Dorchester Wastewater Treatment Facility

Last Updated: Reporting For:

5/26/2021

2020

River or water crossings % of pipe crossings evaluated or maintained

Please include additional comments about your sanitary sewer collection system below:

Continue to monitor I & I. Also if funding works out, replacing 3 blocks sewer lines. Also Phosphorus piloting

3. Performance Indicators

3.1 Provide the following collection system and flow information for the past year.

<input type="text" value="31.65"/>	Total actual amount of precipitation last year in inches
<input type="text" value="27.96"/>	Annual average precipitation (for your location)
<input type="text" value="8.766"/>	Miles of sanitary sewer
<input type="text" value="3"/>	Number of lift stations
<input type="text" value="0"/>	Number of lift station failures
<input type="text" value="0"/>	Number of sewer pipe failures
<input type="text" value="1"/>	Number of basement backup occurrences
<input type="text" value="1"/>	Number of complaints
<input type="text"/>	Average daily flow in MGD (if available)
<input type="text"/>	Peak monthly flow in MGD (if available)
<input type="text"/>	Peak hourly flow in MGD (if available)

3.2 Performance ratios for the past year:

<input type="text" value="0.00"/>	Lift station failures (failures/year)
<input type="text" value="0.00"/>	Sewer pipe failures (pipe failures/sewer mile/yr)
<input type="text" value="0.00"/>	Sanitary sewer overflows (number/sewer mile/yr)
<input type="text" value="0.11"/>	Basement backups (number/sewer mile)
<input type="text" value="0.11"/>	Complaints (number/sewer mile)
<input type="text"/>	Peaking factor ratio (Peak Monthly:Annual Daily Avg)
<input type="text"/>	Peaking factor ratio (Peak Hourly:Annual Daily Avg)

4. Overflows

LIST OF SANITARY SEWER (SSO) AND TREATMENT FACILITY (TFO) OVERFLOWS REPORTED **

Date	Location	Cause	Estimated Volume
None reported			

** If there were any SSOs or TFOs that are not listed above, please contact the DNR and stop work on this section until corrected.

5. Infiltration / Inflow (I/I)

5.1 Was infiltration/inflow (I/I) significant in your community last year?

Yes

No

If Yes, please describe:

5.2 Has infiltration/inflow and resultant high flows affected performance or created problems in your collection system, lift stations, or treatment plant at any time in the past year?

Yes

No

Compliance Maintenance Annual Report

Dorchester Wastewater Treatment Facility

Last Updated: Reporting For:
5/26/2021 2020

If Yes, please describe: <input type="text"/>
5.3 Explain any infiltration/inflow (I/I) changes this year from previous years: <input type="text" value="Because of being a little dryer and lower ground water level, not as much I & I as in the past several years"/>
5.4 What is being done to address infiltration/inflow in your collection system? <input type="text" value="Looking at replacing 2 to 3 blocks of sewer main replacement if funding is there"/>

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Dorchester Wastewater Treatment Facility

Last Updated: Reporting For:
5/26/2021 2020

Grading Summary

WPDES No: 0021571

SECTIONS	LETTER GRADE	GRADE POINTS	WEIGHTING FACTORS	SECTION POINTS
Influent	B	3	3	9
BOD/CBOD	A	4	10	40
TSS	A	4	5	20
Ammonia	A	4	5	20
Phosphorus	A	4	3	12
Ponds	A	4	7	28
Biosolids	A	4	5	20
Staffing/PM	A	4	1	4
OpCert	A	4	1	4
Financial	A	4	1	4
Collection	A	4	3	12
TOTALS			44	173
GRADE POINT AVERAGE (GPA) = 3.93				

Notes:

- A = Voluntary Range (Response Optional)
- B = Voluntary Range (Response Optional)
- C = Recommendation Range (Response Required)
- D = Action Range (Response Required)
- F = Action Range (Response Required)

Compliance Maintenance Annual Report

Dorchester Wastewater Treatment Facility

Last Updated: Reporting For:

5/26/2021

2020

Resolution or Owner's Statement

Name of Governing
Body or Owner:

Date of Resolution or
Action Taken:

Resolution Number:

Date of Submittal:

ACTIONS SET FORTH BY THE GOVERNING BODY OR OWNER RELATING TO SPECIFIC CMAR SECTIONS (Optional for grade A or B. Required for grade C, D, or F):

Influent Flow and Loadings: Grade = B

Effluent Quality: BOD: Grade = A

Effluent Quality: TSS: Grade = A

Effluent Quality: Ammonia: Grade = A

Effluent Quality: Phosphorus: Grade = A

Ponds: Grade = A

Biosolids Quality and Management: Grade = A

Staffing: Grade = A

Operator Certification: Grade = A

Financial Management: Grade = A

Collection Systems: Grade = A

(Regardless of grade, response required for Collection Systems if SSOs were reported)

ACTIONS SET FORTH BY THE GOVERNING BODY OR OWNER RELATING TO THE OVERALL GRADE POINT AVERAGE AND ANY GENERAL COMMENTS

(Optional for G.P.A. greater than or equal to 3.00, required for G.P.A. less than 3.00)

G.P.A. = 3.93